Phone: 080-22945350 **Email:**cewwmwest@bwssb.gov.in

BENGALURU WATER SUPPLY AND SEWERAGE BOARD
Office of the Chief Engineer (Used Water Projects)
6th Floor, Cauvery Bhavan, KG Road, Bangalore - 560009

No. BWSSB/ CE(UWP)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/79 /2025-26Dt: 23/12/25

CORRIGENDUM/ADDENDUM

Sub: Tender for the Work of providing sewerage system to intercept sewage from laterals and HSC's directly discharging to V-303 and its connected SWD's across the catchment area of Kathriguppe valley under package-04.

Ref: Tender IFT No: BWSSB/CE(WWM-W)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/1750/2025-26 Dated: 09.12.2025.

~*~*~*~

With reference to the above subject, invitation for the tender was invited vide IFT mentioned in reference letter. This Corrigendum / Addendum indicates the replies to pre bid Queries for the above tender.

Chief Engineer(UWP)
BWSSB

Encl: Replies to the pre bid Queries.

REPLY TO PRE-BID QUERIES FOR Tender for the Work of providing sewerage system to intercept sewage from laterals and HSC's directly discharging to V-303 and its connected SWD's across the catchment area of Kathriguppe valley under package-04.

Tender:BWSSB/CE(WWM-W)/ACE(WWM-VV-W)/DCE(WWM-E&W)/TA-2/1750/2025-26 Dated: 09.12.2025 BWSSB/2025-26/WS/WORK_INDENT3017

Sl. No	Document Name	Page No/Section Name	Statement	Query	Submitted on	Reply
1.	Relaxation for Tender conditions	Tender Documents Page No 5	Requesting for the Relaxation of diameter pipe and pipe to be relaxed to DWC/RCC PIPES	This tenders Technical qualification Criteria has to be relaxed for lower diameter pipes and DWC/RCC PIPES so that competive price is arrived which shall benifit board and contractors at same time	19-12-2025 11:24:07	Refer Addendum
2	Relaxation for Tender conditions	Tender Documents Page No 5 and 8	Requesting to consider 800mm RCC pipe and above and DWC HDPE pipe or RCC NP-3 Pipe	To ensure more competitive bidding and cost efficiency for the Board it is Requested that the technical qualification criteria be relaxed for lower diameter and DWC and RCC pipes This adjustment will expand the bidder pool benefiting both the Board and prospective contractors	19-12-2025 11:31:55	Refer Addendum

ACE(WWM-VV-W)
BWSSB

Chief Engineer(UWP)
BWSSB

Addendum/Corrigendum

1. Tender No: BWSSB/2025-26/WS/Work_INDENT3007
2. Tender No: BWSSB/2025-26/WS/Work_INDENT3016
3. Tender No: BWSSB/2025-26/WS/Work_INDENT3017
4. Tender No: BWSSB/2025-26/WS/Work_INDENT3018
5. Tender No: BWSSB/2025-26/WS/Work_INDENT3019
6. Tender No: BWSSB/2025-26/WS/Work_INDENT3020
7. Tender No: BWSSB/2025-26/WS/Work_INDENT3026

SL.No	**Approved PQ Criteria**	**Relaxation PQ Criteria**
1	300mm dia and above DWC HDPE pipe.	300mm dia and above DWC HDPE pipe /RCC NP-3 Class Sewer.
2	400mm dia and above DWC HDPE pipe.	400mm dia and above DWC HDPE pipe / RCC NP-3 Class Sewer.
3	1000 mm dia and above RCC NP-3 class sewer	900 mm dia and above RCC NP-3 class sewer
4	1200 mm dia and above RCC NP-3 class sewer	900 mm dia and above RCC NP-3 class sewer
5	1600 mm dia and above MS Casing pipe through Trenchless Technology	1200 mm dia and above MS Casing pipe through Trenchless Technology

ACE(WWM-H&A.V-W)
BWSSB

ACE(WWM-V.V-W)
BWSSB

CE(UWP)
BWSSB